

IEC 61850 Certificate - IEC 61850 Certificate #6706

STP-K120

02/10/2024 11:35 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	24TC200080_Sanion_IED_STP-K120_ServerEd2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: A86CC79A0583AE27EA35679CDB158 CCE5EBA70221536A92E1FE2D221FD9 D65F6
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sanion Co., Ltd.	Vendor Artifact Hash:	
Address:	13, Geomdan-ro, 114-gil, Seo-gu, Incheon, 22663, Republic of Korea	Umbrella Organization:	
Product:	STP-K120	Optional Reservation Test:	Yes
HW Version:	2.00	Serial Number:	IED-STP-K120-2023-1001
SW Version:	2.00	Publisher Legacy Variants:	-
Key Words:	Relay	Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	02/10/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
Transformer protection			

Files

24TC200080_Sanion_IED_STP-K120_ServerEd2_KERI.pdf	705 KB	02/10/2024	Herbert Falk
---	--------	------------	--------------