

# IEC 61850 Certificate - IEC 61850 Certificate #6707

## SLP-K140

02/11/2024 10:55 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	24TC200079_Sanion_IED_SLP-K140_ServerEd2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: D19C380F4F41DF2258AC4E62755DBE 0036060AE7DC4C89982B41E5D51CD0 239F
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Sanion Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	13, Geomdan-ro, 114-gil, Seo-gu, Incheon, 22663, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	SLP-K140	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	2.00	<b>Serial Number:</b>	IED-SLP-K140-2023-1001
<b>SW Version:</b>	2.00	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	02/11/2024	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			
Transmission line protection			

### Files

24TC200079_Sanion_IED_SLP-K140_ServerEd2_KERI.pdf	705 KB	02/11/2024	Herbert Falk
---	--------	------------	--------------