

# IEC 61850 Certificate - IEC 61850 Certificate #6715

## ETR600-BC

02/24/2024 10:29 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	24TC200145_EntecEnE_IED_ETR600-BC_Server_Ed2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 937AE5CB4E097F24E0099CB970BC31 A062617602B038E18A003A200837D78 0EB
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	ENTEC Electric & Electronic, Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	225-38 Choirubaek-ro, Bongdam-eup, Hwasung-city, Gyeonggi-do, 18329, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	ETR600-BC	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	1.0.0.2	<b>Serial Number:</b>	R22120001
<b>SW Version:</b>	2.0.0.1	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	02/24/2024	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			

### Files

24TC200145_EntecEnE_IED_ETR600-BC_Server_Ed2_KERI.pdf	507 KB	02/24/2024	Herbert Falk
---	--------	------------	--------------