

IEC 61850 Certificate - IEC 61850 Certificate #6717

PowerLogic™ P5F30 protection relays

02/24/2024 10:42 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-04-CAV-013 P5F30_IEC 61850Ed2_Server_2.0.6_Certificate_Final.pdf
61850 Edition:	Edition 2 Amd 1	Certificate Hash:	SHA256: 80C22ED729105B68F4C93AF9830D42 6F80592935266A81D6AB414F3D292E3 641
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric	Vendor Artifact Hash:	
Address:	35 Rue Joseph Monier, 92500 Rueil-Malmaison, France	Umbrella Organization:	
Product:	PowerLogic™ P5F30 protection relays	Optional Reservation Test:	Yes
HW Version:		Serial Number:	
SW Version:	V02.501	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	02/24/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Taiwan Testing and Certification Center (A)		
Description			

Files

23-04-CAV-013 P5F30_IEC 61850Ed2_Server_2.0.6_Certificate_Final.pdf 28 MB

02/24/2024

Herbert Falk