

IEC 61850 Certificate - IEC 61850 Certificate #6719

SPiN-CNAS

02/24/2024 10:58 AM - Herbert Falk

Status:	Approved	Test Document:	Edition2 Client Test Procedures version 1.2
Priority:	Normal	Certificate Name:	24TC200132_DAEWOONG_SA-ICD_SPiN-CNAS_Client_Ed2_KERI.pdf
61850 Edition:	Edition 2	Certificate Hash:	24TC200132_DAEWOONG_SA-ICD_SPiN-CNAS_Client_Ed2_KERI.pdf
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	DAEWOONG ELECTRIC Co., Ltd.	Vendor Artifact Hash:	
Address:	Hwanggeumro 127beon-gil 10, Yangchon-eup, Gimpo-si, Gyeonggi-do, 10048, Republic of Korea	Umbrella Organization:	
Product:	SPiN-CNAS	Optional Reservation Test:	No
HW Version:	1.0.0/SPiN-SC2	Serial Number:	DWE-SNGW2301
SW Version:	1.0.0	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	02/24/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
SA-ICD (Substation Automation Information Connecting Device)			

History

#1 - 02/24/2024 11:11 AM - Herbert Falk

- HW Version changed from SPiN-SC2 to 1.0.0/SPiN-SC2

Files

24TC200132_DAEWOONG_SA-ICD_SPiN-CNAS_Client_Ed2_KERI.pdf 66 KB

02/24/2024

Herbert Falk