

# IEC 61850 Certificate - IEC 61850 Certificate #6721

## SPiN-MDAS

02/24/2024 11:09 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	24TC200134_DAEWOONG_SA-IMD_S PiN-MDAS_Server_Ed2_KERI.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	24TC200134_DAEWOONG_SA-IMD_S PiN-MDAS_Server_Ed2_KERI.pdf
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	DAEWOONG ELECTRIC Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Hwanggeumro 127beon-gil 10, Yangchon-eup, Gimpo-si, Gyeonggi-do, 10048, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	SPiN-MDAS	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	1.0.0	<b>Serial Number:</b>	DWE-SNSD2301
<b>SW Version:</b>	1.0.0/SPin-SD2	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	02/24/2024	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Xuchang KETOP Testing Research Institute Co.(A)		

### Description

SA-IMD (Substation Automation Information Monitoring & Diagnosis Device)

### Files

24TC200134\_DAEWOONG\_SA-IMD\_SPiN-MDAS\_Server\_Ed2\_KERI.pdf 506 KB 02/24/2024 Herbert Falk