

Client - Issues #6727

cDsN1bc, cFtN2 have no non-Ed2 specific error code

03/05/2024 06:26 AM - Richard Schimmel

Status: Resolved	Due date:
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID:
61850 Standard: 8-1	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: TP1.2	
Description	
Same as for cSrvN10 also cDsN1b/cDsN1c (MMS GetNameList) and cFtN2 (MMS fileDirectory) have no Ed1 specific error code. I propose to deprecate these test cases just like cSrvN10.	
Related issues:	
Related to Client - Issues #6688: cSrvN10 - Ed1 specific error codes do not e...	Resolved 04/02/2024

History

#1 - 03/05/2024 06:26 AM - Richard Schimmel

- Related to Issues #6688: cSrvN10 - Ed1 specific error codes do not exist for MMS GetNameList added

#2 - 04/02/2024 08:42 AM - IEC 61850 TPWG

- Status changed from New to Resolved

- Assignee set to Richard Schimmel

Accepted. Tp to be deprecated.