

IEC 61850 Certificate - IEC 61850 Certificate #6732

ETMDU1000

03/11/2024 08:34 AM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-070016-05-1_ENTEC_ETMDU1000_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 0F66A75D776DFA82574A3FD88B373D A1CBB7D6C3F1764CF31778A1F852E1 747F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ENTEC Electric & Electronic Co., Ltd.	Vendor Artifact Hash:	
Address:	225-38, Choerubaek-ro, Bongdam-eup, Hwaseong-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	ETMDU1000	Optional Reservation Test:	Yes
HW Version:	ETMDU1000	Serial Number:	22070002
SW Version:	1.0.0.1	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	03/11/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			

History

#1 - 03/11/2024 08:39 AM - Herbert Falk

- Optional Reservation Test changed from No to Yes

Files

23-070016-05-1_ENTEC_ETMDU1000_Server_Ed2_Certification_KTL.pdf 103 KB 03/11/2024 Herbert Falk