

IEC 61850 Certificate - IEC 61850 Certificate #6740

ALARM ANNUNCIATOR MBAS 0600

03/24/2024 01:50 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	CPRI_Minilec India Pvt Ltd_CPRI BLRSGRL24TC0005.pdf
61850 Edition:	Edition 2	Certificate Hash:	SHA256: 888AEAEA288AB5E6397759C4BC60A7 41DD74D043FF85E8C64564ADCC5899 09D4
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Minilec(India) Pvt.Ltd.	Vendor Artifact Hash:	
Address:	S.No.1073/1,2,3, Post - Pirangoot,Taluka- Mulshi,Dist-Pune,Maharashtra,Pin-4121 11,India.	Umbrella Organization:	
Product:	ALARM ANNUNCIATOR MBAS 0600	Optional Reservation Test:	Yes
HW Version:	1.0	Serial Number:	0D0001
SW Version:	1.0	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Buffered Reporting (B6), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	03/24/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		

Description
MBAS 0600 Microprocessor/ Microcontroller Based Alarm Annunciator is designed to keep an alert and watchful eye on plant and processes. It is equipped with super bright LED facia windows , site selectable, programmed sequences as per ISA standard and optional customize sequences.

Files			
CPRI_Minilec India Pvt Ltd_CPRI BLRSGRL24TC0005.pdf	800 KB	03/24/2024	Herbert Falk