

IEC 61850 Certificate - IEC 61850 Certificate #6741

SA-G3000

03/24/2024 02:09 PM - Herbert Falk

Status:	Approved	Test Document:	Edition 2 Server Test Procedures version 2.0.6
Priority:	Normal	Certificate Name:	23-084308-04-1_PNC_SA-G3000_Server_Ed2_Certification_KTL.pdf
61850 Edition:	Edition 2	Certificate Hash:	23-084308-04-1_PNC_SA-G3000_Server_Ed2_Certification_KTL.pdf
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	PNC Technologies Co.,Ltd.	Vendor Artifact Hash:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea, 14042	Umbrella Organization:	
Product:	SA-G3000	Optional Reservation Test:	Yes
HW Version:	2	Serial Number:	PNC-SA-D0-2311-0001
SW Version:	1	Publisher Legacy Variants:	-
Key Words:		Publisher Preferred Rates:	-
Test Procedure Version:	2.0.6	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	-
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Variants:	
Approval Date:	03/24/2024	Subscriber Preferred Rates:	-
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			

History

#1 - 03/24/2024 02:10 PM - Herbert Falk

- *Optional Reservation Test changed from No to Yes*

Files

23-084308-04-1_PNC_SA-G3000_Server_Ed2_Certification_KTL.pdf 121 KB 03/24/2024 Herbert Falk