

# IEC 61850 Certificate - IEC 61850 Certificate #6742

## V321 Arc Flash Protection System

03/24/2024 02:15 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Server Test Procedure version 2.0.6
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	D 089191 0047_Schneider_V321_IEC61850Ed2_Server_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 0CE7F82C40061BDBE904A31219F9B5 8FA688E24255418B992A535EB61568D D73
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric Industries SAS	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	35 rue Joseph Monier, 92500 Rueil Malmaison, France	<b>Umbrella Organization:</b>	
<b>Product:</b>	V321 Arc Flash Protection System	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	V2.7	<b>Serial Number:</b>	EB233940062
<b>SW Version:</b>	V20.200	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	2.0.6	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/24/2024	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD China Ltd (A)		
<b>Description</b>			

### History

#1 - 03/24/2024 02:16 PM - Herbert Falk

- *Optional Reservation Test changed from No to Yes*

### Files

D 089191 0047\_Schneider\_V321\_IEC61850Ed2\_Server\_Certificate.pdf 92 MB

03/24/2024

Herbert Falk