

# IEC 61850 Certificate - IEC 61850 Certificate #6746

## DW61850CLIENT

03/29/2024 09:00 AM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	Edition 2 Client Test Procedures version 1.2
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	24-017428-01-1_DONGWOO_DW61850 CLIENT_Client_Ed2_Certificate_KTL.pdf
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	SHA256: 9083217C473D7CA06F5E148F8E8CD3 1075404F74F3F727B3A39F05CD49452 9CF
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	DONGWOO ELECTRIC CORP.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	34, Oseongseo-ro, Anjung-eup, Pyeongtaek-si, Gyeonggi-do, Republic of Korea, 17928	<b>Umbrella Organization:</b>	
<b>Product:</b>	DW61850CLIENT	<b>Optional Reservation Test:</b>	Yes
<b>HW Version:</b>	1.0 (HP Z2 Workstation )	<b>Serial Number:</b>	DW61850-202410
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Rates:</b>	-
<b>Test Procedure Version:</b>	1.2	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	-
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/29/2024	<b>Subscriber Preferred Rates:</b>	-
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		

### Description

SA-OPD (Substation Automation Operation Software)

### History

#1 - 03/29/2024 09:07 AM - Herbert Falk

- Optional Reservation Test changed from No to Yes

### Files

24-017428-01-1\_DONGWOO\_DW61850CLIENT\_Client\_Ed2\_Certificate\_KTL.pdf 36.5 KB

03/29/2024

Herbert Falk