

Server - Issues #6749

Clarification of ExtRef attributes usage - TISSUE 1818

04/02/2024 08:16 AM - IEC 61850 TPWG

| | |
|---------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|
| Status: Closed | Due date: 04/16/2024 |
| Priority: High | |
| Assignee: Richard Schimmel | |
| Category: | |
| Target version: | |
| Discuss in Upcoming Meeting: No | Updated Test Document: |
| Clause Reference: | Test Case ID: sCnf43, tSci2 |
| 61850 Standard: 6 | Closed Reason: Test Procedure Update |
| Triggering Tissue: https://iec61850.tissue-db.com/tissues/1818 | Triggering Tissue 2: |
| Final Decision: | Triggering Tissue 3: |
| Initial Test Document: | |
| Description | |
| Verify extRef usage according to updated table 51. | |
| sCnf43 | |
| Also impacts SCT tSci2 | |

History

#1 - 04/16/2024 05:39 AM - Richard Schimmel

- File Solution to redmine 6749 ExtRef tissue 1818.docx added
- Test Case ID set to sCnf43, tSci2

Updated sCnf43 attached with text from the tissue:

Updated presence condition of ExtRef attributes based on the context:

- For later binding (in ICD or IID) all attributes related to subscribed data are forbidden: "iedName", "IdInst", "prefix", "InClass", "InInst", "doName", "daName", "srcLDInst", "srcPrefix", "srcLNClass", "srcLNInst", "srcCBName"
- for signal mapping, attributes "daName" and "desc" are always optional

#2 - 04/16/2024 08:31 AM - IEC 61850 TPWG

- File Solution to redmine 6749 ExtRef tissue 1818.docx added
- Status changed from In Progress to Resolved
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set--)

Update solution accepted.

#3 - 06/10/2024 04:21 AM - Richard Schimmel

- Status changed from Resolved to Closed

Files

| | | | |
|--------------------------------------------------|---------|------------|------------------|
| Solution to redmine 6749 ExtRef tissue 1818.docx | 21.9 KB | 04/16/2024 | Richard Schimmel |
| Solution to redmine 6749 ExtRef tissue 1818.docx | 22.2 KB | 04/16/2024 | IEC 61850 TPWG |