

## Server - Issues #6750

### sAddr length - TISSUE 1885

04/02/2024 08:20 AM - IEC 61850 TPWG

<b>Status:</b> Closed	<b>Due date:</b> 04/16/2024
<b>Priority:</b> High	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b>
<b>Clause Reference:</b>	<b>Test Case ID:</b> sCnf53
<b>61850 Standard:</b> 6	<b>Closed Reason:</b> Test Procedure Update
<b>Triggering Tissue:</b> <a href="https://iec61850.tissue-db.com/tissues/1885">https://iec61850.tissue-db.com/tissues/1885</a>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b>	
<b>Description</b>	
validate max length (not yet limited in 2.1 schema)	
requires new test procedure.	

#### History

##### #1 - 04/02/2024 09:24 AM - IEC 61850 TPWG

- Subject changed from sAddr length to sAddr length - TISSUE 1885

##### #2 - 04/16/2024 05:26 AM - Richard Schimmel

- File Solution to redmine 6750 sAddr.docx added

- Test Case ID set to sCnf53

Add new test case sCnf53 applicable for both server ICT and server test procedures

##### #3 - 04/16/2024 08:17 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

- Closed Reason Test Procedure Update added

- Closed Reason deleted (--Not Set--)

##### #4 - 06/10/2024 04:23 AM - Richard Schimmel

- Status changed from Resolved to Closed

#### Files

Solution to redmine 6750 sAddr.docx

20.7 KB

04/16/2024

Richard Schimmel