

IEC 61850 Certificate - IEC 61850 Certificate #6754

N60

04/07/2024 11:06 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 50745.6UR.808_GE_N60_8.51_Ed2_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: AB2B797552326E4662772579227284E3C82495C9CB729EB1BBD7FDD5D10C6E45
Company:	GE Renewable Energy Ltd.	Vendor Artifact File Name:
Address:	St. Leonards Building, Harry Kerr Drive Stafford, ST16 1WT United Kingdom	Vendor Artifact Hash:
Product:	N60	Umbrella Organization:
HW Version:		Optional Reservation Test: Yes
SW Version:	8.51	Serial Number: S/N AAIC15000574
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	04/07/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Grid Automation Laboratories (B)	Product Variants: UR B30
Test Document:	Edition 2 Server Test Procedures version 2.0.6	Time Activated Control:
Description GE Multilin N60 Network Stability and Synchrophasor Measurement System		

History

#1 - 04/30/2024 08:37 AM - Herbert Falk

- Product Variants set to UR B30

Files

