

IEC 61850 Certificate - IEC 61850 Certificate #6755

Multilin N60

04/07/2024 11:11 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-4098_DNV_GE_Multilin N60_B30_F35_C60_B90_ServerEd2_C ertificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: 86E902CBA09CD96FFF2ECD9C3A984 2A4C340D4C122E20CD9EB2B822D1D D7F5EE
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	GE Renewable Energy	Umbrella Organization:	
Address:	"650 Markland St. Markham ON L6C OM1 Canada"	Optional Reservation Test:	Yes
Product:	Multilin N60	Serial Number:	S/N: AAKC20000120
HW Version:		Publisher Legacy Variants:	-
SW Version:	8.5.1	Publisher Preferred Rates:	-
Key Words:	Relay	Publisher Preferred Variants:	
Test Procedure Version:	2.0.6	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	04/07/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:	Edition 2 Server Test Procedures version 2.0.6		
Description Network Stability and Synchrophasor Measurement System			

Files

24-4098_DNV_GE_Multilin N60_B30_F35_C60_B90_ServerEd2_Certificate.pdf

04/07/2024

Herbert Falk