

IEC 61850 Certificate - IEC 61850 Certificate #6760

SEL-751 and SEL-787L (Variant)

04/15/2024 06:52 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-4064_DNV_SEL_751_787L_ServerEd2_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: 2CDB72D80121EB3D81D52C4124B96 D82171BA05E4C71E8FF1B43EA2A547 CC26F
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Schweitzer Engineering Laboratories, Inc	Umbrella Organization:	
Address:	2350 NE Hopkins Court Pullman WA 99163-5603 USA	Optional Reservation Test:	Yes
Product:	SEL-751 and SEL-787L (Variant)	Serial Number:	3240095161
HW Version:		Publisher Legacy Variants:	-
SW Version:	Firmware version: SEL-751-R401 IEC 61850 library ID: 27A190B2	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.0.6	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	04/15/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:	Edition 2 Server Test Procedures version 2.0.6		
Description Feeder Protection Relay			

Files

24-4064_DNV_SEL_751_787L_ServerEd2_Certificate.pdf	108 KB	04/15/2024	Herbert Falk
--	--------	------------	--------------