

IEC 61850 User Feedback Task Force - Bug #6767

Specifying virtualized physical devices and LN's

04/17/2024 10:45 AM - Dustin Tessier

Status:	New	Start date:	04/17/2024
Priority:	Normal	Due date:	
Assignee:	Christophe CAMELIS	% Done:	0%
Category:		Estimated time:	0.00 hour
Target version:		To discuss in WG10:	No
ID:		Short Proposal:	
Source:		Standard(s):	
TF Unique ID:		Needs More Information:	No
WG10 Proposal:		Assigned TF:	61850-7-3
Estimated Completion:			
Discuss in Upcoming Meeting:	No		

Description

During a recent vPAC Alliance meeting we discussed how to differentiate a virtualized physical device and a virtualized LN. Similar to how we must differentiate proxied physical using the LPHD.Proxy, and mirrored LN using the LN.Mir, we may need a new DO to specify when a physical device is virtualized (e.g. LPHD.Vir) and when a LN is virtualized(LN.Vir). This will likely be handled through the virtualization TF, but would like to capture this gap so it is addressed in the future.

History

#1 - 04/17/2024 10:45 AM - Dustin Tessier

- Subject changed from Specifying virtualized LD and LN to Specifying virtualized physical devices and LN's