

IEC 61850 Certificate - IEC 61850 Certificate #6770

EdgeHub DataWorX

04/24/2024 02:00 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-012366-01-1_LS ELECTRIC_EdgeHub_Client_Ed2_Certificate_KTL.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: C921420370979FF7A8D6C22FF1E1319 E522840A9AF612DD969EEF0577B398 97D
Company:	LS ELECTRIC	Vendor Artifact File Name:
Address:	LS ELECTRIC R&D Center, 40, LS-ro 116beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea, 14118	Vendor Artifact Hash:
Product:	EdgeHub DataWorX	Umbrella Organization:
HW Version:	16ARH7H	Optional Reservation Test: Yes
SW Version:	2.01.0002	Serial Number: LS_EHDWX_201
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	04/24/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Client Test Procedures version 1.2	Time Activated Control:
Description EdgeHub DataWorX is SW that acts as a bridge between IT and OT areas. DataWorX collect/process/save data from various types of equipment in the OT area. You can build a system that provides data to IT area.		

Files

24-012366-01-1_LS ELECTRIC_EdgeHub_Client_Ed2_Certificate_KTL.pdf	871KB	04/24/2024	Herbert Falk
---	-------	------------	--------------