

IEC 61850 Certificate - IEC 61850 Certificate #6771

EcoStruxure Foxboro SCADA SCD6000 CPU

04/28/2024 08:33 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-4115_DNV_SE_SCD6000_ClientEd2_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: 085992215BAB168F117A87EC8B86232 5CF6F9D88DA6AD864A10FDC5B617D 56B3
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Client	Vendor Artifact Hash:	
Company:	Schneider Electric Systems USA, Inc.	Umbrella Organization:	
Address:	70 Mechanic Street Foxboro, Massachusetts 02035-2040 United States of America	Optional Reservation Test:	No
Product:	EcoStruxure Foxboro SCADA SCD6000 CPU	Serial Number:	
HW Version:	SY-60399008R	Publisher Legacy Variants:	-
SW Version:	18.0.2 SY-1101207_R1	Publisher Preferred Rates:	-
Key Words:	RTU	Publisher Preferred Variants:	
Test Procedure Version:	1.2	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	04/28/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:	Edition 2 Client Conformance Test Procedures version 1.2		

Description

Related issues:

Copied to IEC 61850 Certificate - IEC 61850 Certificate #6772: EcoStruxure Fo...

Approved

History

#1 - 04/28/2024 08:38 AM - Herbert Falk

- Copied to IEC 61850 Certificate #6772: EcoStruxure Foxboro SCADA SCD6000 CPU added

#2 - 04/30/2024 08:28 AM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

Files

24-4115_DNV_SE_SCD6000_ClientEd2_Certificate.pdf	109 KB	04/28/2024	Herbert Falk
--	--------	------------	--------------