

# IEC 61850 Certificate - IEC 61850 Certificate #6772

## EcoStruxure Foxboro SCADA SCD6000 CPU

04/28/2024 08:38 AM - Herbert Falk

<p><b>Status:</b> Approved</p> <p><b>Priority:</b> Normal</p> <p><b>61850 Edition:</b> Edition 2 Amd 1</p> <p><b>61850 Tested Aspects:</b> Server</p> <p><b>Company:</b> Schneider Electric Systems USA, Inc.</p> <p><b>Address:</b> 70 Mechanic Street Foxboro, Massachusetts 02035-2040 United States of America</p> <p><b>Product:</b> EcoStruxure Foxboro SCADA SCD6000 CPU</p> <p><b>HW Version:</b> SY-60399008R</p> <p><b>SW Version:</b> 18.0.2 SY-1101207_R1</p> <p><b>Key Words:</b> RTU</p> <p><b>Test Procedure Version:</b> 1.2</p> <p><b>IEC 61850 Blocks Certified:</b> Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time sync SNTP (B13a), Unbuffered Reporting (B5)</p> <p><b>Certificate/Result Reviewer:</b> Herbert Falk</p> <p><b>Approval Date:</b> 04/28/2024</p> <p><b>Standards Tested:</b> 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1</p> <p><b>Current Test Lab Name:</b> DNV Netherlands (A)</p> <p><b>Test Document:</b> Edition 2 Server Test Procedures Edition 2 with Amendment 1 version 1.2</p>	<p><b>Certificate Name:</b> 24-4092_DNV_SE_SCD6000_ServerEd 2Amd1_Certificate.pdf</p> <p><b>Certificate Hash:</b> SHA256: 5DA79E691BDDD0411EBB70D7DD077 5F0D722E09D1DED836335C7D2831D4 E009F</p> <p><b>Vendor Artifact File Name:</b></p> <p><b>Vendor Artifact Hash:</b></p> <p><b>Umbrella Organization:</b></p> <p><b>Optional Reservation Test:</b> Yes</p> <p><b>Serial Number:</b></p> <p><b>Publisher Legacy Variants:</b> -</p> <p><b>Publisher Preferred Rates:</b> -</p> <p><b>Publisher Preferred Variants:</b></p> <p><b>Subscriber Legacy Variants:</b> -</p> <p><b>Subscriber Preferred Variants:</b></p> <p><b>Subscriber Preferred Rates:</b> -</p> <p><b>Product Variants:</b></p>
<p><b>Description</b></p>	
<p><b>Related issues:</b> Copied from IEC 61850 Certificate - IEC 61850 Certificate #6771: EcoStruxure ... <span style="float: right;"><b>Approved</b></span></p>	

### History

#1 - 04/28/2024 08:38 AM - Herbert Falk

- File 24-4092\_DNV\_SE\_SCD6000\_ServerEd2Amd1\_Certificate.pdf added

- Copied from IEC 61850 Certificate #6771: EcoStruxure Foxboro SCADA SCD6000 CPU added

**Files**

---

24-4092_DNV_SE_SCD6000_ServerEd2Amd1_Certificate.pdf	105 KB	04/28/2024	Herbert Falk
--	--------	------------	--------------