

Client - Issues #6776

cSBOs4 requires different control value

04/30/2024 04:30 AM - Richard Schimmel

Status: In Progress	Due date: 05/28/2024
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID:
61850 Standard: 8-1	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: Ed2Am1 1p0	
Description	
<p>Step 3 states "repeat step 1 and 2 with the same CDC with a different control value". The SBOs Select does not contain a control value. In the server SBOs we verify that the server does ignore the control value. So the control value in the Cancel doesn't matter at all.</p> <p>We propose to remove step 3.</p>	

History

#1 - 04/30/2024 08:11 AM - IEC 61850 TPWG

- Due date set to 05/28/2024
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

Accepted.

#2 - 05/06/2024 08:44 AM - Richard Schimmel

- File Solution to redmine 6776 cSBOs4.docx added

Attached solution

Files

Solution to redmine 6776 cSBOs4.docx	21.8 KB	05/06/2024	Richard Schimmel
--------------------------------------	---------	------------	------------------