

# IEC 61850 Certificate - IEC 61850 Certificate #6782

## iCE-CPU

05/03/2024 02:49 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	24-4147_DNV_ETAP_iCE-CPU_Server Ed2_Certificate.pdf
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	SHA256: 1F6C0468F65587D99CF82888F26B24C 23388818CAC06E5125E0CCEEDBAFF 2C56
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	ETAP	<b>Umbrella Organization:</b>	
<b>Address:</b>	17 Goodyear Irvine California 92618 USA	<b>Optional Reservation Test:</b>	Yes
<b>Product:</b>	iCE-CPU	<b>Serial Number:</b>	23194605
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	-
<b>SW Version:</b>	Firmware version: 4.20.0 IEC 61850 version: s61850 3.0.0	<b>Publisher Preferred Rates:</b>	-
<b>Key Words:</b>	RTU	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	2.0.6	<b>Subscriber Legacy Variants:</b>	-
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Rates:</b>	-
<b>Approval Date:</b>	05/03/2024	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6		

### Description

Intelligent Remote Terminal Unit

### History

#1 - 05/03/2024 02:51 PM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

**Files**

24-4147\_DNV\_ETAP\_iCE-CPU\_ServerEd2\_Certificate.pdf

99.2 KB

05/03/2024

Herbert Falk