

IEC 61850 Certificate - IEC 61850 Certificate #6783

CCI Power Plant Controller

05/03/2024 03:02 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-4141_DNV_Thytronic_CCI_ServerEd 2_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 28C92640AAAAAB905949F96360BE2FF 1865704D3FACA1F65E03947F66B75A C577
Company:	Thytronic s.p.a.	Vendor Artifact File Name:
Address:	Piazza Mistral 7, 20139 Milan, Italy	Vendor Artifact Hash:
Product:	CCI Power Plant Controller	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	Firmware version: 4.20.0 IEC 61850 version: s61850 3.0.0	Serial Number: 23194605
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	05/03/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 Server Test Procedures version 2.0.6	Time Activated Control:
Description Power Plant Controller		

History

- #1 - 05/03/2024 03:02 PM - Herbert Falk
- 61850 Edition Edition 2 added
 - 61850 Edition deleted (Edition 2 Amd 1)

Files

