

IEC 61850 Certificate - IEC 61850 Certificate #6790

YH-HSA-ICD

05/19/2024 11:47 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-001371-01-1_YOUHO_YH-HSA-ICD_Client_Ed2_Certification_KTL.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 0582BE8A6523867F95128FC26B2A5D1 82B83C87AA9AB381D682795E0E6C2D 940
Company:	YOUHO Electric Ind CO., Ltd.	Vendor Artifact File Name:
Address:	39-42, 1253 BEON-GIL, GWONYUL-RO, BAEKSEOK-EUP, YANGJU-SI, GYEONGGI-DO, Republic of Korea, 14042	Vendor Artifact Hash:
Product:	YH-HSA-ICD	Umbrella Organization:
HW Version:	ADVANTECH ECU-4784	Optional Reservation Test: Yes
SW Version:	1	Serial Number: YH-HSA-ICD-24001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	05/19/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Client Test Procedures version 1.2	Time Activated Control:
Description Substation Automation Information Connecting Device		
Related issues: Related to IEC 61850 Certificate - IEC 61850 Certificate #6791: YH-HSA-ICD Approved		

History

#1 - 05/19/2024 11:53 AM - Herbert Falk

- Related to IEC 61850 Certificate #6791: YH-HSA-ICD added

Files

24-001371-01-1_YOUHO_YH-HSA-ICD_Client_Ed2_Certification_KTL.pdf	1.67 KB	05/19/2024	Herbert Falk
--	---------	------------	--------------