

IEC 61850 Certificate - IEC 61850 Certificate #6791

YH-HSA-ICD

05/19/2024 11:53 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-001371-01-2_YOUHO_YH-HSA-ICD_Server_Ed2_Certification_KTL.pdf
Priority:	Normal	Certificate Hash:	SHA256: 4263B17B2661AC73EFD68FD6B8C292 53E61371ADBC4C78E65E3A64C2FEC 07430
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	YOUHO Electric Ind CO., Ltd.	Umbrella Organization:	
Address:	39-42, 1253 BEON-GIL, GWONYUL-RO, BAEKSEOK-EUP, YANGJU-SI, GYEONGGI-DO, Republic of Korea, 14042	Optional Reservation Test:	Yes
Product:	YH-HSA-ICD	Serial Number:	YH-HSA-ICD-24001
HW Version:	ADVANTECH ECU-4784	Publisher Legacy Variants:	-
SW Version:	1	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.0.6	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	05/19/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	Korea Testing Laboratory (A)		
Test Document:	Edition 2 Server Test Procedures version 2.0.6		
Description			
Substation Automation Information Connecting Device			
Related issues:			
Related to IEC 61850 Certificate - IEC 61850 Certificate #6790: YH-HSA-ICD			Approved

History

#1 - 05/19/2024 11:53 AM - Herbert Falk

- Related to IEC 61850 Certificate #6790: YH-HSA-ICD added

Files

24-001371-01-2_YOUHO_YH-HSA-ICD_Server_Ed2_Certification_KTU1701.pdf

05/19/2024

Herbert Falk