

IEC 61850 Certificate - IEC 61850 Certificate #6794

P3F60

05/26/2024 09:05 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-4173_DNV_Schneider_PowerLogicP3F60_ServerEd2_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 6C7D239A6C1D6A46840B1105D8D970 65CEF94F8BB606BCE7341B22EF5B24 2E77
Company:	Schneider Electric Industries SAS	Vendor Artifact File Name:
Address:	"35 rue Joseph Monier 92500 Rueil Malmaison France"	Vendor Artifact Hash:
Product:	P3F60	Umbrella Organization:
HW Version:		Optional Reservation Test: Yes
SW Version:	V01	Serial Number: WX2351404100006
Key Words:	Feeder	Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	05/26/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 Servert Test Procedures version 2.0.6	Time Activated Control:
Description Feeder Protection relay		

Files

24-4173_DNV_Schneider_PowerLogicP3F60_ServerEd2_Certificate.pdf	07 KB	05/26/2024	Herbert Falk
---	-------	------------	--------------