

## Server - Issues #6795

### sCnf29 all subnetworks used for 61850 shall have type 8-MMS

05/28/2024 03:29 AM - Richard Schimmel

<b>Status:</b> Closed	<b>Due date:</b>
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b>
<b>Clause Reference:</b>	<b>Test Case ID:</b> sCnf29
<b>61850 Standard:</b> 6	<b>Closed Reason:</b> Test Procedure Update
<b>Triggering Tissue:</b>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b> Ed2.1 TP1.2	

**Description**

Some devices have separate network interfaces for MMS, GOOSE and SMV, with unique types(!). All these subnetworks shall have the same type "8-MMS".

The current sCnf29 only requires "at least one" subnetwork has type 8-MMS. Such device would incorrectly pass the test

Proposal:  
Verify that all IEC 61850 related SubNetwork type's have value "8-MMS" when type is present or type is absent

#### History

##### #1 - 05/28/2024 08:58 AM - IEC 61850 TPWG

- Status changed from New to Resolved
- Assignee set to Richard Schimmel

Accepted

##### #2 - 06/10/2024 09:25 AM - Richard Schimmel

- Status changed from Resolved to Closed
- Closed Reason Test Procedure Update added
- Closed Reason deleted (--Not Set--)