

## Server - Issues #6797

### 1765 IED can only have one basic namesapce

05/28/2024 08:04 AM - IEC 61850 TPWG

<b>Status:</b> Closed	<b>Due date:</b>
<b>Priority:</b> Normal	
<b>Assignee:</b> Richard Schimmel	
<b>Category:</b>	
<b>Target version:</b>	
<b>Discuss in Upcoming Meeting:</b> No	<b>Updated Test Document:</b>
<b>Clause Reference:</b>	<b>Test Case ID:</b> sCnf82
<b>61850 Standard:</b> 7-1	<b>Closed Reason:</b> Test Procedure Update
<b>Triggering Tissue:</b> <a href="https://iec61850.tissue-db.com/tissues/1765">https://iec61850.tissue-db.com/tissues/1765</a>	<b>Triggering Tissue 2:</b>
<b>Final Decision:</b>	<b>Triggering Tissue 3:</b>
<b>Initial Test Document:</b>	
<b>Description</b>	

#### History

##### #1 - 06/06/2024 04:16 AM - Richard Schimmel

- Test Case ID set to sCnf82

Current sCnf82:

Verify for each LLN0 that if LLN0.NamPlt.IdNs is present it shall have value IEC 61850-7-4:2007B (and IdNs is valid domain name space), otherwise LLN0.NamPlt.IdNs shall have value IEC 61850-7-4:2007B.

Proposal sCnf82:

Verify for each LLN0 that if LLN0.NamPlt.IdNs is present it shall have value IEC 61850-7-4:2007B (and IdNs is valid domain name space), otherwise each **non-proxy** LLN0.NamPlt.IdNs in the IED shall have **the same** value IEC 61850-7-4:2007B **or an inclusion name space**

##### #2 - 06/11/2024 08:35 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

##### #3 - 06/11/2024 09:30 AM - Richard Schimmel

- Status changed from Resolved to Closed

- Closed Reason Test Procedure Update added

- Closed Reason deleted (--Not Set--)