

IEC 61850 Certificate - IEC 61850 Certificate #6804

MRZS-F

06/10/2024 08:15 AM - Herbert Falk

Status:	Approved	Certificate Name:	24-4160_DNV_POE_MRZS-F_ServerEd2_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: F9867229BF401700C3BBB7F288C69D 2DD1FF5CBE8FEE1C3434408A7091A9 9880
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	POE "SPE "PROMAVTOMATICA"	Umbrella Organization:	
Address:	03067, c.Kyiv, street Harmatna, 2 Ukraine	Optional Reservation Test:	Yes
Product:	MRZS-F	Serial Number:	1888
HW Version:		Publisher Legacy Variants:	-
SW Version:	1.0.0.18	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	2.0.6	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	06/10/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Time Activated Control:	
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:	Edition 2 Server Test Procedures version 2.0.6		
Description			
Microprocessor Protection, Automation, Monitoring and Control Device			

Files

24-4160_DNV_POE_MRZS-F_ServerEd2_Certificate.pdf	97.8 KB	06/10/2024	Herbert Falk
--	---------	------------	--------------