

IEC 61850 Certificate - IEC 61850 Certificate #6805

SEL-2411

06/10/2024 08:24 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-4169_DNV_SEL_2411_2414_ServerEd2_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: F06187F2C31229C60A4E898465E14C3 26D2DB43F764301ED3AD2E3FC1CB3 0681
Company:	Schweitzer Engineering Laboratories, Inc.	Vendor Artifact File Name:
Address:	2350 NE Hopkins Court 99163 Pullman WA United States of America	Vendor Artifact Hash:
Product:	SEL-2411	Umbrella Organization:
HW Version:		Optional Reservation Test: Yes
SW Version:	Firmware version: SEL-2411-R501, IEC 61850 library ID: 0E57F003	Serial Number: 3240195504
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	06/10/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants: SEL-2411, SEL-2414
Test Document:	Edition 2 Server Test Procedures version 2.0.6	Time Activated Control:
Description Programmable Automation Controller		

Files

24-4169_DNV_SEL_2411_2414_ServerEd2_Certificate.pdf	103 KB	06/10/2024	Herbert Falk
---	--------	------------	--------------