

IEC 61850 Certificate - IEC 61850 Certificate #6812

SA-T8000

06/19/2024 10:06 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 23-084306-01-1_PNC_SA-T8000_Client_Ed2_Certification_KTL.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 30A57A9F8460ABB75362149BA34C07 F4E3B657D033E1D2CE522B420A635B E8C7
Company:	PNCTechnologies Co.,Ltd.	Vendor Artifact File Name:
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea, 14042	Vendor Artifact Hash:
Product:	SA-T8000	Umbrella Organization:
HW Version:	1	Optional Reservation Test: Yes
SW Version:	2	Serial Number: PNC-SA-T0-2311-0001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	06/19/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Client Test Procedure version 1.2	Time Activated Control:
Description		

Files

23-084306-01-1_PNC_SA-T8000_Client_Ed2_Certification_KTL.pdf	126 KB	06/19/2024	Herbert Falk
--	--------	------------	--------------