

IEC 61850 Certificate - IEC 61850 Certificate #6813

SA-G2000

06/19/2024 10:11 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 23-084307-01-1_PNC_SA-G2000_Client_Ed2_Certification_KTL.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 8A57CB09C93B34FA4E6B9CFF240284 352AAF0302079EBAC3901E17D96F6F 6F5B
Company:	PNCTechnologies Co.,Ltd.	Vendor Artifact File Name:
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea, 14042	Vendor Artifact Hash:
Product:	SA-G2000	Umbrella Organization:
HW Version:	1	Optional Reservation Test: No
SW Version:	2	Serial Number: PNC-SA-G0-2311-0001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	06/19/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Client Test Procedure version 1.2	Time Activated Control:
Description SA-ICD (Substation Automation Information Connecting Device)		
Related issues: Related to IEC 61850 Certificate - IEC 61850 Certificate #6814: SA-G2000		
		Approved

History

#1 - 06/19/2024 10:17 AM - Herbert Falk

- Related to IEC 61850 Certificate #6814: SA-G2000 added

Files

23-084307-01-1_PNC_SA-G2000_Client_Ed2_Certification_KTL.pdf	125 KB	06/19/2024	Herbert Falk
--	--------	------------	--------------