

IEC 61850 Certificate - IEC 61850 Certificate #6814

SA-G2000

06/19/2024 10:16 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 23-084307-01-2_PNC_SA-G2000_Server_Ed2_Certification_KTL.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 858A5E7BFDDDD581DFA93A6842D5EB F98A02ACDF719064CA55A269260942 8D8F5
Company:	PNCTechnologies Co.,Ltd.	Vendor Artifact File Name:
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea, 14042	Vendor Artifact Hash:
Product:	SA-G2000	Umbrella Organization:
HW Version:	1	Optional Reservation Test: Yes
SW Version:	2	Serial Number: PNC-SA-G0-2311-0001
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	2.0.6	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Service Tracking (B15), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	06/19/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Server Test Procedure version 2.0.6	Time Activated Control:
Description		
Related issues:		
Related to IEC 61850 Certificate - IEC 61850 Certificate #6813: SA-G2000		Approved

History

- #1 - 06/19/2024 10:17 AM - Herbert Falk
- Related to IEC 61850 Certificate #6813: SA-G2000 added

Files

