

IEC 61850 Certificate - IEC 61850 Certificate #6818

TAS-GW

06/30/2024 09:11 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-032850-01-2_KMData_TAS-GW_Client_Ed2_TP_1p2_Certificate_KTL.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 6B047DB19D1CBD9151037D89529C93 CFD068CEC71B10050C6C8404AB2989 EED0
Company:	KMData Inc.	Vendor Artifact File Name:
Address:	505-2, Daeryung Techno Town 1-cha 18, Gasam Digital 2-ro, Geumcheon-gu, Seoul, Republic of Korea, 08592	Vendor Artifact Hash:
Product:	TAS-GW	Umbrella Organization:
HW Version:	1.0/ECU-4784	Optional Reservation Test: No
SW Version:	1.0/Windows Server 2019	Serial Number: SA102404001E
Key Words:	Gateway	Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	06/30/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 Client Test Procedures version 1.2	Time Activated Control:
Description Gateway device for substation automation		

Files

24-032850-01-2_KMData_TAS-GW_Client_Ed2_TP_1p2_Certificate_KTL.pdf	06/30/2024	Herbert Falk
--	------------	--------------