

Status:	New	Start date:	07/05/2024
Priority:	Normal	Due date:	
Assignee:		% Done:	0%
Category:			
Target version:			
Source:		TF 7-5 Project document:	IEC 61850-7-500
Category:	Expansion of existing section	Related TISSUE:	
Description The present clause 11.1.3 mentions "process interface nodes". At the time of creating the TR, the work of IEC/PAS 61850-90-29 was not started. The be discussed whether a re-wording of the clause is necessary. Note that IEC/PAS 61850-90-29 is not yet published. Figure 12 and Figure 23 to be discussed under the same above aspect.			

History

#1 - 07/26/2024 03:02 AM - Michael Haecker

- Category changed from Not yet categorized to Expansion of existing section

TF 7-500 (2024-07-25)

Assessment: This is a valid action item. The model of PAS/IEC 61850-90-29 shall be considered even in 7-500 based on Ed.2.1 .
--> Reworking of clause 11.1.3/Figures to be addressed in the TF work plan.