

IEC 61850 Certificate - IEC 61850 Certificate #6828

DRTS 66L

07/16/2024 12:16 PM - Herbert Falk

Status:	Approved	Certificate Name:	C4009637 Altanova I.S.A. DRTS 66L IEC 61869-9 SV Publish - Certificate.PDF
Priority:	Normal	Certificate Hash:	SHA256: 50B3F33907EAF1989C707F117CA7C1 93CBA9376F1FE43E7D93738D4970FB A2AA
61850 Edition:	Edition 2 Amd 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Sampled Values	Vendor Artifact Hash:	
Company:	I.S.A. Altanova Group S.r.l.	Umbrella Organization:	
Address:	Via Prati Bassi, 22 21020 Taino (VA) ITALY	Optional Reservation Test:	No
Product:	DRTS 66L	Serial Number:	
HW Version:	1.0D	Publisher Legacy Variants:	F12800S8I14U4, F15360S8I4U4, F4000S1I4U4, F4800S1I4U4
SW Version:	2.03 - Communication v.1.6 Build 136	Publisher Preferred Rates:	F14400S6, F4800S2
Key Words:	Merging Unit, Test Tool	Publisher Preferred Variants:	F4000S1I0-12U0-12; F4800S1I0-12U0-12; F4800S2I0-12U0-12; F5760S1I0-12U0-12; F12800S8I0-4U0-4; F14400S6I0-4U0-4; F15360S8I0-4U0-4
Test Procedure Version:	1.2	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Sampled Value Publish (11a)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	07/16/2024	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1, 61850-9-2, 61869-9	Time Activated Control:	
Current Test Lab Name:	CESI S.p.A. – KEMA Labs (A)		
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2		
Description			

Files

C4009637 Altanova I.S.A. DRTS 66L IEC 61869-9 SV Publish - Certificate.PDF

07/16/2024

Herbert Falk