

# IEC 61850 Certificate - IEC 61850 Certificate #6829

## Easergy MiCOM P849

07/16/2024 12:24 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	SchneiderElectric_MiCOM P849_B5_ServerEd2_Certificate.pdf
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	SchneiderElectric_MiCOM P849_B5_ServerEd2_Certificate.pdf
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Schneider Electric Industries SAS	<b>Umbrella Organization:</b>	
<b>Address:</b>	35 rue Joseph Monier, 92500 Rueil -Maimaison, France	<b>Optional Reservation Test:</b>	Yes
<b>Product:</b>	Easergy MiCOM P849	<b>Serial Number:</b>	39717614
<b>HW Version:</b>	M	<b>Publisher Legacy Variants:</b>	-
<b>SW Version:</b>	B5	<b>Publisher Preferred Rates:</b>	-
<b>Key Words:</b>	Relay	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	2.0.6	<b>Subscriber Legacy Variants:</b>	-
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Rates:</b>	-
<b>Approval Date:</b>	07/16/2024	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Time Activated Control:</b>	
<b>Current Test Lab Name:</b>	Schneider-Electric China (B)		
<b>Test Document:</b>	Edition 2 Server Test Procedures version 2.0.6		
<b>Description</b> MiCOM P849			

### Files

SchneiderElectric_MiCOM P849_B5_ServerEd2_Certificate.pdf	566 KB	07/16/2024	Herbert Falk
---	--------	------------	--------------