

# IEC 61850 Certificate - IEC 61850 Certificate #6833

## SA-IMD DWSA-WATCHER

08/06/2024 01:00 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	24-045125-01-2_DongWoo_DWSA-WAT CHER_Server_Ed2.1_Certification_KTL. pdf
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	SHA256: 132392124FCD4400D0047B8457EF9E5 ECCC3BFF48BCDD259F48C1A21A541 0F24
<b>61850 Edition:</b>	Edition 2 Amd 1	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	DONGWOO ELECTRIC CORP	<b>Umbrella Organization:</b>	
<b>Address:</b>	34, Oseongseo-ro, Anjung-eup, Pyeongtaek-si, Gyeonggi-do, Republic of Korea, 17928	<b>Optional Reservation Test:</b>	Yes
<b>Product:</b>	SA-IMD DWSA-WATCHER	<b>Serial Number:</b>	DWSA-WATCHER-2024-001
<b>HW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	-
<b>SW Version:</b>	1.0	<b>Publisher Preferred Rates:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.2	<b>Subscriber Legacy Variants:</b>	-
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), File Transfer (B14), Time sync SNTP (B13a), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Rates:</b>	-
<b>Approval Date:</b>	08/06/2024	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Time Activated Control:</b>	
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Test Document:</b>	Edition 2 with Amendment 1 Server Test Procedures version 1.2		
<b>Description</b> Substation Automation Information Monitoring & Diagnosis Device			
<b>Related issues:</b> Related to IEC 61850 Certificate - IEC 61850 Certificate #6834: SA-IMD DWSA-W... <b>Approved</b>			

### History

#1 - 08/06/2024 01:05 PM - Herbert Falk

- Related to IEC 61850 Certificate #6834: SA-IMD DWSA-WATCHER added

#2 - 08/06/2024 01:05 PM - Herbert Falk

- Optional Reservation Test changed from No to Yes

**Files**

24-045125-01-2\_DongWoo\_DWSA-WATCHER\_Server\_Ed2.1\_CertificateKTL.pdf 08/06/2024

Herbert Falk