

IEC 61850 Certificate - IEC 61850 Certificate #6841

DM100

08/08/2024 02:20 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 24-4229_DNV_MikroDev_DM100Controller_clientEd2_Certificate.pdf
61850 Tested Aspects:	Client	Certificate Hash: SHA256: E8FD0C6A91E7A93E5FCCEF61C91D3991B894269C94800A2D5CC21B99A564AC08
Company:	Mikrodev Billisim Yazilm Eltektronic	Vendor Artifact File Name:
Address:	Cumhuriyet Mh. Turgut Ozal Cd. No:26 41420 Cayirova Kocaeli, Turkey	Vendor Artifact Hash:
Product:	DM100	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	19.01	Serial Number:
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	08/08/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 Client Test Procedures version 1.2	Time Activated Control:
Description Controller		

History

#1 - 08/08/2024 02:23 PM - Herbert Falk

- Address updated