

IEC 61850 Certificate - IEC 61850 Certificate #6884

UC 500 S

08/23/2024 09:24 AM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 24-4188_DNV_Efacec_UC500_clientEd2Amd1_Certificate
61850 Tested Aspects:	Client	Certificate Hash: SHA256: 241347762A6F256EBC70446FE7AE1D 1CE5E2BF64ADB9F9B5A2575DFB9E2 9DD0E
Company:	Efacec Energia	Vendor Artifact File Name:
Address:	Maquinas e Equipamentos Electricos, S.A. Via de Francisco Sa Carneiro 4471-907 Moreira da Maia	Vendor Artifact Hash:
Product:	UC 500 S	Umbrella Organization:
HW Version:		Optional Reservation Test: Yes
SW Version:	3.1.7	Serial Number: 954434
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.0	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	08/23/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Client Conformance Test Procedures version 1.0	Time Activated Control:
Description Station Server		

History

- #1 - 08/27/2024 05:43 PM - Herbert Falk
- Certificate Name changed from 24-4188_DNV_Efacec_UC500_ClientEd2Amd1_Certificate.pdf to 24-4188_DNV_Efacec_UC500_clientEd2Amd1_Certificate

- Certificate Hash changed from SHA256: 4EBC762DDD1DA0DDE94D8624696DB48477C611D0EF8F27315651B6FE7311EB33 to SHA256:

#2 - 08/27/2024 05:43 PM - Herbert Falk

- File deleted (24-4188_DNV_Efacec_UC500_ClientEd2Amd1_Certificate.pdf)

#3 - 08/27/2024 05:43 PM - Herbert Falk

- File 24-4188_DNV_Efacec_UC500_clientEd2Amd1_Certificate.pdf added

Files

24-4188_DNV_Efacec_UC500_clientEd2Amd1_Certificate.pdf	107 KB	08/27/2024	Herbert Falk
--	--------	------------	--------------