

IEC 61850 Certificate - IEC 61850 Certificate #6887

REF650

08/27/2024 05:26 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 24-4125_DNV_HITACHI_REF650_ServerEd2Amd1_Certificate
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 4EAA72B7B81B0CD75C0EAD5A0CBA53280ACDD731E85E6AC1508B49DB812D9E56
Company:	Hitachi Energy Sweden AB	Vendor Artifact File Name:
Address:	SE-721 59 Vasteras Sweden	Vendor Artifact Hash:
Product:	REF650	Umbrella Organization:
HW Version:	3.0.1	Optional Reservation Test: Yes
SW Version:	0.5.23.286	Serial Number: T2344092
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Substitution (B3), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	08/27/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control:
Description Multi-application feeder protection and control		
Related issues: Copied to IEC 61850 Certificate - IEC 61850 Certificate #6888: REF650		
		Approved

History

- #1 - 08/27/2024 05:31 PM - Herbert Falk
- Copied to IEC 61850 Certificate #6888: REF650 added

Files

24-4125_DNV_HITACHI_REF650_ServerEd2Amd1_Certificate.pdf	107 KB	08/27/2024	Herbert Falk
--	--------	------------	--------------