

Server - Issues #6897

sCnf7, sCnf66 services can be defined on IED and AccessPoint when identical

09/04/2024 07:39 AM - Richard Schimmel

Status:	Resolved	Due date:	11/12/2024
Priority:	Normal		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	No	Updated Test Document:	
Clause Reference:	Table 50	Test Case ID:	sCnf7, sCnf66
61850 Standard:	6	Closed Reason:	--Not Set--
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:		Triggering Tissue 3:	
Initial Test Document:	TP1.3		
Description			
Part 6 - Table 50 defines exactly what Services - Elements - Attributes are allowed on IED level and AccessPoint level. It also indicates if the value shall be identical or may be different.			
Proposal: Verify that Services at IED and AccessPoint level match the requirements as defined in IEC 61850-6 Table 50.			

History

#1 - 09/05/2024 07:27 AM - Richard Schimmel

- Subject changed from sCnf7 services can be defined on IED and AccessPoint when identical to sCnf7, sCnf66 services can be defined on IED and AccessPoint when identical
- Clause Reference set to Table 50
- Initial Test Document set to TP1.3
- Test Case ID set to sCnf7, sCnf66
- 61850 Standard 6 added

Propose to merge sCnf7 and sCnf66 into sCnf7.

#2 - 10/29/2024 08:50 AM - IEC 61850 TPWG

- Due date set to 11/12/2024
- Status changed from New to In Progress
- Assignee set to Richard Schimmel

Accepted. Richard to add proposal.

#3 - 10/30/2024 04:25 AM - Richard Schimmel

- File Solution to redmine 6897 sCnf7-sCnf66.docx added

Solution attached

#4 - 11/12/2024 08:31 AM - IEC 61850 TPWG

- Status changed from In Progress to Resolved

Accepted.

Files

