

Client - Issues #6902

cLogN5 has no Ed1 specific error code

09/11/2024 02:27 AM - Richard Schimmel

Status:	Resolved	Due date:	11/12/2024
Priority:	Normal		
Assignee:	Richard Schimmel		
Category:			
Target version:			
Discuss in Upcoming Meeting:	No	Updated Test Document:	
Clause Reference:		Test Case ID:	
61850 Standard:	7-2	Closed Reason:	--Not Set--
Triggering Tissue:		Triggering Tissue 2:	
Final Decision:		Triggering Tissue 3:	
Initial Test Document:	Client Amd1 TP1.0		
Description			
Same as for cSrvN10 also the cLogN5 QueryLogByTime/After has no Ed1 specific error code. I propose to deprecate this test case just like cSrvN10.			

History

#1 - 10/29/2024 08:51 AM - IEC 61850 TPWG

- Due date set to 11/12/2024
- Status changed from New to Resolved
- Assignee set to Richard Schimmel

Accepted.