

Server - Issues #6989

sSvp14 for Backwards the max MSVID is 34 char not 32

09/20/2024 06:29 AM - Richard Schimmel

Status: Resolved	Due date:
Priority: Normal	
Assignee: Richard Schimmel	
Category:	
Target version:	
Discuss in Upcoming Meeting: No	Updated Test Document:
Clause Reference:	Test Case ID: sSvp14
61850 Standard: 9-2	Closed Reason: --Not Set--
Triggering Tissue:	Triggering Tissue 2:
Final Decision:	Triggering Tissue 3:
Initial Test Document: TP1.3	

Description

9-2LE figure 4 shows SVID 10..34 chars. The maximum length is 34 chars! The test case states 32 chars as maximum length.

Proposal: update step 1 from '32' to '34' char

History

#1 - 10/29/2024 08:56 AM - IEC 61850 TPWG

- Status changed from New to Resolved
- Assignee set to Richard Schimmel