

IEC 61850 Certificate - IEC 61850 Certificate #6998

SIPROTEC 5 7ST86

09/20/2024 12:59 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 24-4268_DNV_SIEMENS_SIPROTEC_7ST86_ServerEd2Amd1_Certificate.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: 36FF1093A43D2087FC5432368B87479 87FDBD4669591E45666D6ADF171BDE 910
Company:	Siemens AG	Vendor Artifact File Name:
Address:	Wernerwerkdammm 5 13629 Berlin Germany	Vendor Artifact Hash:
Product:	SIPROTEC 5 7ST86	Umbrella Organization:
HW Version:		Optional Reservation Test: Yes
SW Version:	V9.80	Serial Number: BM2211009943
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time sync PTP (B13b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	09/20/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control:
Description Railway protection		

Files

24-4268_DNV_SIEMENS_SIPROTEC_7ST86_ServerEd2Amd1_Certificate.pdf	09/20/2024	Herbert Falk
--	------------	--------------