

IEC 61850 Certificate - IEC 61850 Certificate #6999

DRTS 66L

09/22/2024 02:06 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: C4011484 - Doble Engineering Company - DRTS 66L IEC 61869 SV Publisher certification - Certificate.pdf
61850 Tested Aspects:	Sampled Values	Certificate Hash: SHA256: 3AFE6A6A89138547D7857F8E43628541 33A4FF0B4ACBA645AE5DBF728BD24 6DB1
Company:	DOBLE Engineering Company	Vendor Artifact File Name:
Address:	123 Felton Street Marlborough, MA 01752 USA	Vendor Artifact Hash:
Product:	DRTS 66L	Umbrella Organization:
HW Version:	1.0D	Optional Reservation Test: No
SW Version:	2.03 - Communication v.1.6 Build 136	Serial Number: TECW01DRTS66L
Key Words:	Merging Unit, Test Set	Publisher Legacy Variants: F12800S8I14U4, F4000S1I4U4, F4800S1I4U4, F5760S1I4U4
Test Procedure Version:	1.2	Publisher Preferred Rates: -, F14400S6, F4800S2
IEC 61850 Blocks Certified:	Basic Exchange (B1)	Publisher Preferred Variants: F4000S1I0-12U0-12; F4800S1I0-12U0-12; F4800S2I0-12U0-12; F5760S1I0-12U0-12; F12800S8I0-4U0-4; F14400S6I0-4U0-4; F15360S8I0-4U0-4
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	09/22/2024	Subscriber Preferred Variants:
Standards Tested:	61850-8-1, 61850-9-2, 61869-9	Subscriber Preferred Rates: -
Current Test Lab Name:	CESI S.p.A. – KEMA Labs (A)	Product Variants:
Test Document:	dition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control:
Description		

Files

C4011484 - Doble Engineering Company - DRTS 66L IEC 61869 SV Publisher certification - Certificate.pdf	Herbert Falk
--	--------------