

# IEC 61850 Certificate - IEC 61850 Certificate #7000

## KSE(Kepco Substation Explorer)

09/22/2024 02:19 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	24-041130-01-1_KEPCO_KSE_Client_Ed2.0_Certification_KTL.pdf
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	SHA256: E0CF854F1C3A61878DE989F206284C 1B4675C46DC79180A66A1D8C8F090F EEE7
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	Korea Electric Power Corporation	<b>Umbrella Organization:</b>	
<b>Address:</b>	105 Munji-ro, Daejeon	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	KSE(Kepco Substation Explorer)	<b>Serial Number:</b>	
<b>HW Version:</b>	HP ZBOOK Power G9	<b>Publisher Legacy Variants:</b>	-
<b>SW Version:</b>	1.0/OS : Windows 10 Pro	<b>Publisher Preferred Rates:</b>	-
<b>Key Words:</b>		<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.2	<b>Subscriber Legacy Variants:</b>	-
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Control Block (9), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	Herbert Falk	<b>Subscriber Preferred Rates:</b>	-
<b>Approval Date:</b>	09/22/2024	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	<b>Time Activated Control:</b>	
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Test Document:</b>	Edition 2 Client Test Procedures version 1.2		
<b>Description</b> KEPCO Test Tool			

### History

#1 - 09/22/2024 07:14 PM - Herbert Falk

- 61850 Edition Edition 2 added

- 61850 Edition deleted (Edition 2 Amd 1)

- 61850 Tested Aspects Client added

- 61850 Tested Aspects deleted (Server)

**Files**

---

24-041130-01-1\_KEPCO\_KSE\_Client\_Ed2.0\_Certification\_KTL.pdf 126 KB 09/22/2024 Herbert Falk