

IEC 61850 Certificate - IEC 61850 Certificate #7011

MIED12 (Multifunction Protection Relay)

09/30/2024 07:08 AM - Herbert Falk

Status:	Approved	Certificate Name:	CPRI_Megawin Switchgear Private Limited_CPRIBLRSGRL24TC0006_Certificate.pdf
Priority:	Normal	Certificate Hash:	SHA256: C26FC16EA72CFE43B9009227073867 DCA981886A1BFCACFCE15AC98B557 68A05
61850 Edition:	Edition 2 Amd 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	Megawin Switchgear Private Limited	Umbrella Organization:	
Address:	Post Box No.434,Perumal Malai Adivaram,Narasothipatti,Salem-636004	Optional Reservation Test:	Yes
Product:	MIED12 (Multifunction Protection Relay)	Serial Number:	MIED1224060001
HW Version:	1.0	Publisher Legacy Variants:	-
SW Version:	2.0	Publisher Preferred Rates:	-
Key Words:		Publisher Preferred Variants:	
Test Procedure Version:	1.2	Subscriber Legacy Variants:	-
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	Herbert Falk	Subscriber Preferred Rates:	-
Approval Date:	09/30/2024	Product Variants:	
Standards Tested:	61850-8-1	Time Activated Control:	
Current Test Lab Name:	Central Power Research Institute India (A)		
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2		
Description			
IED with the Compliance of IEC 61850 and for Power system protection,Control and automation,measurements and supervision function.			

Files

CPRI_Megawin Switchgear Private Limited_CPRIBLRSGRL24TC0006_0711Certificate.pdf 09/30/2024

Herbert Falk