

IEC 61850 Certificate - IEC 61850 Certificate #7020

TAS-GW

10/06/2024 06:39 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2 Amd 1	Certificate Name: 24-032850-01-4_KMData_TAS-GW_Server_Ed2.1_Certification_KTL.pdf
61850 Tested Aspects:	Server	Certificate Hash: SHA256: BF09AA6367DC4122F7D1EEDBEF21D F7B47F9AD15322B5C5E80E58E825D9 70254
Company:	KMData Inc.	Vendor Artifact File Name:
Address:	505-2, Daeryung Techno Town 1-cha 18, Gasam Digital 2-ro, Geumcheon-gu, Seoul, Republic of Korea, 08592	Vendor Artifact Hash:
Product:	TAS-GW	Umbrella Organization:
HW Version:	1.0	Optional Reservation Test: Yes
SW Version:	1.0	Serial Number: SA102404001E
Key Words:		Publisher Legacy Variants: -
Test Procedure Version:	1.2	Publisher Preferred Rates: -
IEC 61850 Blocks Certified:	Basic Exchange (B1a), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), File Transfer (B14), Service Tracking (B15), Time sync SNTP (B13a), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	Herbert Falk	Subscriber Legacy Variants: -
Approval Date:	10/06/2024	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates: -
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:	Edition 2 with Amendment 1 Server Test Procedures version 1.2	Time Activated Control:
Description Substation Automation Information Connecting Device		
Related issues: Related to IEC 61850 Certificate - IEC 61850 Certificate #7021: TAS-GW Approved		

History

- #1 - 10/06/2024 06:45 PM - Herbert Falk
- Related to IEC 61850 Certificate #7021: TAS-GW added

Files

